

ORDINANCE NO. 5-2015

**AN ORDINANCE OF THE TOWNSHIP OF WALL, COUNTY OF MONMOUTH,
STATE OF NEW JERSEY AMENDING THE CODES OF THE TOWNSHIP OF
WALL, CHAPTER 140-238, WATER SUPPLY**

WHEREAS, the Township of Wall requires that fire hydrants be located within a certain distance of commercial and residential structures as recommended by the New Jersey Uniform Fire Code so as to provide adequate safety measures for the residents of Wall Township;

NOW, THEREFORE, BE IT ORDAINED by the Governing Body of the Township of Wall, County of Monmouth, State of New Jersey as follows:

SECTION ONE. Chapter 140-238 Water Supply, A. (5) Fire Hydrants (a) is hereby amended as follows:

(a) Hydrants shall be spaced to provide necessary fire flow, and the average area per hydrant typically should not exceed 120,000 square feet. In addition, hydrants shall be spaced so that each residence or commercial structure shall be within 400 feet of a hydrant.


SECTION TWO. All ordinances or parts of ordinances in conflict or inconsistent with any part of this Ordinance are hereby repealed to the extent that they are in such conflict or inconsistent.


SECTION THREE. This Ordinance may be renumbered for codification purposes.

SECTION FOUR. In the event that any section, part or provision of this Ordinance shall be held to be unenforceable or invalid by any court, such holding shall not affect the validity of this Ordinance as a whole, or any part thereof, other than the part so held unenforceable or invalid.

SECTION FIVE. This Ordinance shall take effect 20 days after passage and publication as provided by law.

ATTEST:

By: 
Roberta Lang, RMC
Township Clerk

Township of Wall
By: 
George Newberry
Mayor

INTRODUCED: **March 25, 2015**

ADOPTED: **April 22, 2015**