

TOWNSHIP OF WALL
2700 ALLAIRE ROAD
P. O. BOX 1168
WALL, NJ 07719-1168

Paul Rabenda
Construction Official

(732) 449-8444 Ext. 225
FAX (732) 449-8995

SMOKE & CARBON MONOXIDE DETECTOR REQUIREMENTS

In accordance with the UCC Rehabilitation Subcode, Subchapter Six, all rehabilitation work requires the installation of smoke detectors. They must be on each level of the structure, outside each separate sleeping area and in the immediate vicinity of the bedrooms. Carbon Monoxide detectors must be installed in accordance with the Mechanical Subcode. (Fire)

Battery operated detectors are permitted for both.